


# Energy Performance Certificate




Flat 17  
132 Shepherds Bush Road  
LONDON  
W6 7PD

Dwelling type: Mid-floor flat  
Date of assessment: 26 July 2011  
Date of certificate: 26 July 2011  
Reference number: 8899-6723-8230-8816-8922  
Type of assessment: RdSAP, existing dwelling  
Total floor area: 18 m<sup>2</sup>

This home's performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO<sub>2</sub>) emissions.



The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.



The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

## Estimated energy use, carbon dioxide (CO<sub>2</sub>) emissions and fuel costs of this home

|                          | Current                         | Potential                       |
|--------------------------|---------------------------------|---------------------------------|
| Energy use               | 200 kWh/m <sup>2</sup> per year | 200 kWh/m <sup>2</sup> per year |
| Carbon dioxide emissions | 0.7 tonnes per year             | 0.7 tonnes per year             |
| Lighting                 | £15 per year                    | £15 per year                    |
| Heating                  | £171 per year                   | £171 per year                   |
| Hot water                | £55 per year                    | £55 per year                    |

The figures in the table above have been provided to enable prospective buyers and tenants to compare the fuel costs and carbon emissions of one home with another. To enable this comparison the figures have been calculated using standardised running conditions (heating periods, room temperatures, etc.) that are the same for all homes, consequently they are unlikely to match an occupier's actual fuel bills and carbon emissions in practice. The figures do not include the impacts of the fuels used for cooking or running appliances, such as TV, fridge etc.; nor do they reflect the costs associated with service, maintenance or safety inspections. Always check the certificate date because fuel prices can change over time and energy saving recommendations will evolve.



Remember to look for the Energy Saving Trust Recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.

This EPC and recommendations report may be given to the Energy Saving Trust to provide you with information on improving your dwelling's energy performance.

## About this document

The Energy Performance Certificate for this dwelling was produced following an energy assessment undertaken by a qualified assessor, accredited by Elmhurst Energy Systems Ltd, to a scheme authorised by the Government. This certificate was produced using the RdSAP 2009 assessment methodology and has been produced under the Energy Performance of Buildings (Certificates and Inspections) (England and Wales) Regulations 2007 as amended. A copy of the certificate has been lodged on a national register.

Assessor's accreditation number: EES/007831  
Assessor's name: Mr. Paul Cullen  
Company name/trading name: Energy Assessors Partnership Limited  
Address: Sunnyhill House 3-7 Sunnyhill Road London SW16 2UG  
Phone number: 0845 2577128  
Fax number:  
E-mail address: pcullen@teapl.com  
Related party disclosure: No related party

## If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the preceding page. You can get contact details of the accreditation scheme from their website at [www.elmhurstenergy.co.uk](http://www.elmhurstenergy.co.uk) together with details of their procedures for confirming authenticity of a certificate and for making a complaint.

## About the building's performance ratings

The ratings on the certificate provide a measure of the buildings overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used. The average Energy Efficiency Rating for a dwelling in England and Wales is band E (rating 50).

Not all buildings are used in the same way, so energy ratings use standard occupancy assumptions which may be different from the specific way you use your home. Different methods of calculation are used for homes and for other buildings. Details can be found at [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings on the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

## About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.



Click [www.epcadviser.direct.gov.uk](http://www.epcadviser.direct.gov.uk) our online tool which uses information from this EPC to show you how to save money on your fuel bills.

Further information about Energy Performance Certificates can be found under Frequently Asked Questions at [www.epcregister.com](http://www.epcregister.com)

## Recommendations

None

## Further measures to achieve even higher standards

None

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by a reduction in carbon dioxide (CO<sub>2</sub>) emissions.

## Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology; 1 star means least efficient and 5 stars means most efficient. The assessment does not take into consideration the physical condition of any element. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction.

| Element                                                | Description                                | Current performance |               |
|--------------------------------------------------------|--------------------------------------------|---------------------|---------------|
|                                                        |                                            | Energy Efficiency   | Environmental |
| Walls                                                  | Solid brick, as built, insulated (assumed) | ★★★★☆               | ★★★★☆         |
| Roof                                                   | (another dwelling above)                   | —                   | —             |
| Floor                                                  | (other premises below)                     | —                   | —             |
| Windows                                                | Fully double glazed                        | ★★★☆☆               | ★★★☆☆         |
| Main heating                                           | Boiler and radiators, mains gas            | ★★★★☆               | ★★★★☆         |
| Main heating controls                                  | Programmer, room thermostat and TRVs       | ★★★★☆               | ★★★★☆         |
| Secondary heating                                      | None                                       | —                   | —             |
| Hot water                                              | From main system                           | ★★★★☆               | ★★★★☆         |
| Lighting                                               | Low energy lighting in all fixed outlets   | ★★★★★               | ★★★★★         |
| Current energy efficiency rating                       |                                            | C 77                |               |
| Current environmental impact (CO <sub>2</sub> ) rating |                                            | B 85                |               |

## Low and zero carbon energy sources

None

## Renewable Heat Incentive

You could receive 20 years of RHI payments and help reduce carbon emissions by replacing your existing heating system with one that generates renewable heat and, where appropriate, having your loft insulated to 150 mm and cavity walls filled. The energy required for space and water heating shown below would form the basis of the payments. The Department of Energy and Climate Change has up-to date information on technologies supported and the support levels at [www.decc.gov.uk/rhi](http://www.decc.gov.uk/rhi).

This dwelling: Loft insulation not applicable, Cavity walls not present

| Heat demand for RHI          | Existing dwelling | With loft insulation only | With cavity insulation only | With loft and cavity insulation |
|------------------------------|-------------------|---------------------------|-----------------------------|---------------------------------|
| Space heating (kWh per year) | 929               | -                         | -                           | -                               |
| Water heating (kWh per year) | 1,338             |                           |                             |                                 |

### About the cost effective measures to improve this home's performance ratings

Not applicable

### About the further measures to achieve even higher standards

Not applicable

### What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO<sub>2</sub> emissions.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- Close your curtains at night to reduce heat escaping through the windows.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme.
- Check the draught-proofing of windows and replace it if appropriate.
- If you have unused open chimneys consider blocking them off (making provision for a ventilation opening and a cowl on top of the chimney to avoid dampness).

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call 0800 512 012 or visit [www.energysavingtrust.org.uk](http://www.energysavingtrust.org.uk).